

Laboratory and Equipment

Test	n/a - serial: n/a
Measurement date	6/7/2021

Measurement Conditions

Tested c-planes	36 - 10.00°
Tested gamma angles	181 - 1.00°
Input Power	14.41 W

Tested Light Source

Product name	014010
Item No.	
Manufacturer	

Main Light Measurement Results

Output - Total Lumen (Up% / Down%)	1281 lm - 0.0661% / 99.93%
Efficiency	88.9 lm/W
Peak Intensity	626.4 cd
Correlated Color Temperature, CCT	4000 K
Color Rendering Index	CRI 85.0

Polar light distribution diagram